

# WEEKLY TAILGATE: QUALIFIED LINE CLEARANCE ARBORISTS

Week of

## CORPORATE MESSAGE

## QUALIFIED LINE CLEARANCE ARBORISTS



Qualified Line Clearance Tree Trimmers should **inspect the work zone to identify electrical hazards** before operations begin.




**Only qualified line clearance tree trimmers (QLCTT), or trainees under their direct supervision, may work where an electrical hazard exists.**



**Minimum Approach Distances, known as MAD,** must be understood and maintained at all times. This is one of our Keys to Life.



If work cannot be performed without adhering to the MAD, then an **outage must be requested** from the Client.



When trimming or pruning near power lines, maintain **positive control** of limbs at all times.

## SAFETY VIDEOS

English: [vimeo.com/townsendcorp/13ne](https://vimeo.com/townsendcorp/13ne)

Spanish: [vimeo.com/townsendcorp/13ns](https://vimeo.com/townsendcorp/13ns)

GOALS	REGIONAL/LOCAL OPERATIONS
<u>Last Week</u>	
<u>This Week</u>	

## IMPORTANT REMINDER

## DAILY SAFETY NUGGETS

<p><b><u>MONDAY</u></b>            What is the requirement to work within 10' of a power line? You must be either a Qualified Line Clearance Arborist (QLCTT certified) or be working under the "direct observation" of a Qualified Line Clearance Arborist (QLCTT).</p>
<p><b><u>TUESDAY</u></b>            When an arborist is working within 10' of a power line what is required? Visual or voice communication with a second Qualified Line Clearance Tree Trimmer or a QLCTT trainee is required when working within 10' of a power line.</p>
<p><b><u>WEDNESDAY</u></b>            What distance is to be maintained from an energized power line or component? The appropriate minimum approach distance (MAD) for the voltage present.</p>
<p><b><u>THURSDAY</u></b>            What is one method to remove branches that may be touching energized conductors?            A QLCTT or QLCTT Trainee may be able use an insulated tool or a clean dry non-conductor pole pruner to remove the tips of the branches and obtain the proper MAD.</p>
<p><b><u>FRIDAY</u></b>            What is required if you cannot safely trim or remove a tree due to the presence of an energized conductor?            In this case you must call for a planned outage on the line. The tree can be worked once the line is deenergized and grounded.</p>
<p><b><u>SATURDAY</u></b>            According to Table 1 in the tailgate session, what is the minimum approach distance for 13.5Kv while working below 5000' elevation? 2'5"</p>

## DRIVE SAFETY TIP

<p><b><u>Adjust Your Attitude</u></b></p> <ul style="list-style-type: none"> <li>• Leave yourself <i>enough time</i> rather than trying to <i>make good time</i></li> <li>• Put yourself in the other driver's shoes</li> <li>• Take a deep breath and remember escalating a situation will only make things worse.</li> </ul>
--



# QUALIFIED LINE CLEARANCE ARBORISTS

## Weekly Tailgate Sign-in

Company: \_\_\_\_\_ Location: \_\_\_\_\_

Supervisor: \_\_\_\_\_ Date: \_\_\_\_\_

- |           |           |
|-----------|-----------|
| 1. _____  | 21. _____ |
| 2. _____  | 22. _____ |
| 3. _____  | 23. _____ |
| 4. _____  | 24. _____ |
| 5. _____  | 25. _____ |
| 6. _____  | 26. _____ |
| 7. _____  | 27. _____ |
| 8. _____  | 28. _____ |
| 9. _____  | 29. _____ |
| 10. _____ | 30. _____ |
| 11. _____ | 31. _____ |
| 12. _____ | 32. _____ |
| 13. _____ | 33. _____ |
| 14. _____ | 34. _____ |
| 15. _____ | 35. _____ |
| 16. _____ | 36. _____ |
| 17. _____ | 37. _____ |
| 18. _____ | 38. _____ |
| 19. _____ | 39. _____ |
| 20. _____ | 40. _____ |